

Certificate of Compliance

ASTM D178-01

TEST	SPECIFICATIONS	RESULTS
ELECTRICAL PROOF TEST ASTM D178	MIN. 20,000V FOR 1MINUTE	PASS
DIELECTRIC BREAKDOWN TEST ASTM D149	MIN. 30,000V	PASS
03 RESISTANCE TEST METHOD B ASTM D178	ANY VISUAL DEGRADATION	PASS
TENSILE STRENGTH ASTM D412 DIEC	MIN. 700PSI	PASS
ELONGATION ASTM D412 DIEC	MIN. 250%	PASS
TENSION SET ASTM D412 DIE B	MAX. 0.50IN.	PASS
MOISTURE ABSORPTION ASTM D570	MAX INCREASE 3%	PASS
ACCELERATED AGING ASTM D573	MIN. 50% OF ORIGINAL TENSILE STRENGTH	PASS
FLAME RESISTANCE ASTM D178 APPENDIX	MAX. 0.5IN./12.7mm AFTER 30S	PASS
OIL RESISTANCE ASTM D471	MAX. VOLUME INCREASE 4%	PASS

This is to certify that Item # 702.38x3x75BK meets the requirements of the ASTM D178-01 specification as outlined above.

Written by: Wearwell Quality Assurance

Date: 07/22/2019